

Kim Smith

From: James McKenna <oceandivr@gmail.com>
Sent: Friday, August 30, 2019 2:34 PM
To: Kim Smith; Julie Schmidt
Subject: Fwd: [External] 1700 LINCOLN CHURCH PROJECT
Attachments: Chk List Drainage.pdf

----- Forwarded message -----

From: Galbraith, Stephen W <Stephen.Galbraith@illinois.gov>
Date: Fri, Aug 30, 2019 at 2:24 PM
Subject: RE: [External] 1700 LINCOLN CHURCH PROJECT
To: James McKenna <oceandivr@gmail.com>

Jim

The driveway location along Matthew St. is acceptable to IDOT. However, IDOT will require the existing entrance along Lincoln Ave. to be removed via a Highway Permit from IDOT. Also, we will need to review a storm water detention plan for this development. I am the contact person for the IDOT review and the Highway Permit. We will need 5 hard copies of the site plan and 2 hard copies of the storm water detention plan with supporting calculations (see attached checklist) to begin the permit process. You may either U.S. mail your submittals or drop them off on the 9th floor of the Becker Building. If you have any further questions you may contact me at my number below.

Thank you

Steve Galbraith

Illinois Department of Transportation

Bureau of Operations - Access Permits Unit Chief

401 Main Street

Peoria, Illinois 61602

Phone: (309) 671-4475

From: James McKenna <oceandivr@gmail.com>
Sent: Friday, August 30, 2019 1:54 PM
To: Galbraith, Stephen W <Stephen.Galbraith@illinois.gov>
Subject: [External] 1700 LINCOLN CHURCH PROJECT

I DIMENSIONED THE ENTRANCE FROM THE CURB AT LINCOLN INSTEAD OF THE DRIVE LANE

PLEASE CALL WITH COMMENTS OR CONCERNS

JIM MCKENNA

309-696-9490

State of Illinois - CONFIDENTIALITY NOTICE: The information contained in this communication is confidential, may be attorney-client privileged or attorney work product, may constitute inside information or internal deliberative staff communication, and is intended only for the use of the addressee. Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify the sender immediately by return e-mail and destroy this communication and all copies thereof, including all attachments. Receipt by an unintended recipient does not waive attorney-client privilege, attorney work product privilege, or any other exemption from disclosure.